



Shielding around the Dummy Septum15: Original vs. Final design

Sanja Damjanovic, DGS-RP

CERN, April 11, 2013

PS Ejection Region with Local Shielding around the Dummy Septum




Original Shielding, optimized by FLUKA:

- lateral dimension: 120 cm
- longitudinal dimension: 110 cm
- vertical dimension: 210 cm
 - 60 cm top part
 - 60 cm middle
 - 90 cm lower part

Material: Concrete


Final Design for the Local Shielding around the Dummy Septum





R.F. Ortega

- lateral dimension: 200-220 cm
- longitudinal dimension: 98 cm
- vertical dimension: 220 cm


Less compact than the original shielding





external to the machine




FLUKA Geometry of the Final Shielding Design in SS15




Soil, Stainless Steel, Marble, Aluminum, Concrete, Air, Stainless Steel




FLUKA Geometry of the Final Local Shielding in SS15





Stainless Steel , Stainless Steel, Marble, Aluminum, Concrete



Residual dose rates with local shielding in SS15 - original vs. final shielding design -



2-dim projections in x-y plane, averaged over $\Delta z=110\text{cm}$ (middle of SS15) and over $\pm 30\text{ cm}$ in x (around the beam level)





Residual dose rates outside the local shielding qualitatively similar for the two shielding designs

z-beam direction, x-vertical, y-horizontal direction


Residual dose rates with local shielding in SS15 - original vs. final shielding design -

1 dim projections along y (horizontal) at the beam level, averaged over $\Delta z=110$ cm ($-1190 < z < -1080$ cm, middle of SS15)




Residual dose rates outside the local shielding
the same for the two shielding designs

Residual dose rates with local shielding in SS15 - original vs. final shielding design -




1d projections along y (horizontal)
at the beam level within SS15:

a) averaged over $\Delta z = 70$ cm, $-1190 < z < -1120$ cm,
up to the end of the septum tank



b) averaged over $\Delta z = 40$ cm, $-1120 < z < -1080$ cm,
from the end of the septum tank




Residual dose rates outside the
local shielding very similar for the
two shielding designs

- Individual and Collective Dose Estimates for Interventions at the PS SS15 should be evaluated with the final shielding

- Updated information on intervention processes and duration required


1 & 2, REPLACEMENT OF COMPLETE SYSTEM	Specialist	Time and distance	Comments
Venting of sector	TE-VSC	10 mins, remote intervention	
Dismantling of shielding	EN-HE-HH	1 hour, distance >1m	3 persons, 1h/person
Disconnection of upstream and downstream flanges	TE-VSC	5 mins, contact	2 persons, 2.5min/person
Disconnect cabling, compressed air, water cooling, etc	TE-ABT, BE-BI, TE-VSC	10 mins, distance -contact	2 persons, 2.5min/person 1 person (TE-VSC), 5min/person
Removal of tank assembly	TE-ABT, EN-HE-HH	10 mins, distance 1m 2 persons, 2min/person – contact, 8min/person - 1m	Includes removal of support locking mechanisms
Installation of spare	TE-ABT, EN-HE-HH	15 mins, contact	This spare is non radioactive 3 persons, 5min/person
Reconnection of flanges	TE-VSC	10-15 mins	2 persons, 7.5min/person
Reconnection of cables, air, and water cooling.	TE-ABT, BE-BI, TE-VSC	10 mins	3 persons, 10min/person
Leak test	TE-VSC	30 mins	1 person, 30min/person
Installation of shielding	EN-HE-HH	1 hour	3 persons, 1h/person
Testing			








- Identification of all the blocks to be removed for the intervention

Blocks to be removed for the intervention

Original shielding design





Final shielding design




Stainless Steel , Stainless Steel, **Marble**, Aluminum, Concrete

Intervention Scenario 1&2; Action – Disconnection of downstream flange – original vs. final shielding design

1 person (TE-VSC specialist) involved,
time/person = 2.5 min, contact




Original design



Final design

2-dim projections in x-y plane, averaged over $\Delta z=110\text{cm}$
(middle of SS15) and over $\pm 30\text{ cm}$ in x (around the beam level)

Intervention Scenario 1&2; Action - Disconnection of downstream flange – Original vs. Final Shielding



projections along y for the z positions of the downstream and upstream flanges

Residual dose rates at the position of the downstream flange the same for the two shielding designs → same values for the accumulated dose by a person during the intervention


1 person (TE-VSC specialist) involved, time/person = 2.5 min, contact

example - cooling time 3 days

position of 1st person: x=beam level, z=-1075cm; 3 different y-options considered: 1) y=20 cm; 2) y=30cm; y=40cm

accumulated dose by 1st person:

- 1) $3.2\text{mSv/h} \times 2.5\text{min} = 0.13\text{ mSv}$
- 2) $1.4\text{mSv/h} \times 2.5\text{min} = 0.06\text{ mSv}$
- 3) $0.86\text{mSv/h} \times 2.5\text{min} = 0.036\text{ mSv}$




BKP

Individual and Collective Doses Estimated for the Intervention -Replacement of the complete system- at PS SS15

Specialist from Dep/Grp executing	cooling time								
	Accumulated Dose / Person [mSv/person]								
	1h	8h	1 day	3 days	1 week	2 weeks	1 month	40 days	4 months
TE-VSC-1 st	5.86	4.16	2.41	1.12	0.81	0.68	0.57	0.52	0.33
TE-VSC-2 nd	0.68	0.49	0.29	0.15	0.1	0.09	0.07	0.07	0.04
EN-HE-HH-1 st	3.06	2.08	1.22	0.59	0.45	0.39	0.3	0.27	0.15
EN-HE-HH-2 nd	2.24	1.47	0.87	0.44	0.34	0.29	0.22	0.19	0.12
EN-HE-HH-3 rd	2.24	1.47	0.87	0.44	0.34	0.29	0.22	0.19	0.12
TE-ABT-1 st	2.26	1.62	0.95	0.45	0.33	0.28	0.22	0.2	0.125
TE-ABT-2 nd	0.44	0.32	0.17	0.05	0.033	0.028	0.025	0.023	0.017
BE-BI	1.4	1.0	0.58	0.28	0.2	0.17	0.13	0.13	0.08
Collective Dose [mSv] – ‘8 persons’	18.2	12.6	7.4	3.5	2.6	2.2	1.8	1.6	1.0

Minimum waiting time of at least 3 days required

Blocks to be removed for the intervention



roof off

roof plus one
side block off

roof plus two
side blocks off

